

U.S. EMBASSY, ADDIS ABABA

Invitation to Quote PR11550788

The Embassy of the United States of America, Addis Ababa, Ethiopia, invites all eligible bidders to provide a quotation for KOHLER Trailer Generator 35REOZT4, 50 Hz, Diesel, Tier 4 Mobile Generator or equivalent as per the below specifications, Qty 1 each.

- Standby Range (kW/kVA) 24-30/24-37.5
- Prime Range (kW/kVA) 22-28/22-35
- Continuous Range (kW/VA) 22-28/22-35
- Fuel Type Diesel
- Frequency 50 Hz
- Three phase 220/400V
- Speed 1800 RPM
- Alternator Type Brushless, Wound Field
- Engine Manufacturer Kohler
- Emissions Tier 4 Final EPA-Certified for Nonroad Applications
- Sound Levels 67 dB(A) log average @ 7 m (23 ft.) full load at prime rating
- Fuel Capacity/Run Time 60 gal.
- 12V 90A starting Battery.

Each offer MUST contain the following information. Any supplier with incomplete information will be disqualified.

- 1- Requisition # PR11550788 on the subject of the quotation
 - 2- Full address of the supplier
 - 3- Must have Unique Entity Identifier (UEI) number and registered on System Award Management (SAM) at www.sam.gov, please mention your UEI number on your price offer.
 - 4- Delivery place: Addis Ababa or North Brunswick, New jersey 08902
 - 5- Delivery date of the item to the destination
- **Provide detail specification and picture. Please fill/sign and forward the attached NDAA certificate among with the quote.**

Eligible bidders can submit their price quotation including shipping at AddisGSOProcurement@state.gov, POC: Meseret Ayalew (PR11550788) before April 05, 2023 COB.