

U.S. EMBASSY, ADDIS ABABA

Amendment on Bid# PR11497028A0001

A few suppliers have requested clarification on the following line items, please find the answer in yellow under each question.

1. If cable, cable laying and termination in our scope

Answer: Yes

- a. Length of the cable from generator to changeover

Answer: 30M

- b. Laying in underground trench / cable tray / overlay

Answer: Overlay in Conduit

2. Changeover supply and installation

- a. Breakers for tapping mains power and output load in the LV board.

Answer: Existing will be used

- c. Again, length of cable required for main to changeover and changeover to LV Board.

Answer: 2M

3. Earthing require 3nos – 2 for generator and 1 for panel. Existing

- a. Need to know distance of the earthing pits from the equipment's.

Answer: NA

4. Hot air ducting and exhaust extension if the generator is placed inside a room.

Answer: NA